



Certificate of Compliance

Certificate Number: LR 54280-50

SUBMITTOR

Revision: LR 54280-55

Date Issued: June 29, 1998

Issued To: **ABB SACE S.P.A.**
Via Baioni, 35
CP 218
I-24123 Bergamo
Italy

The products listed below are eligible to bear the CSA Mark.

Issued By: J. Pankowski, P. Eng.
Montreal, PQ, CANADA

Signature

PRODUCTS

PART A

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breakers, Type S7H, S7L and S7N.

These are three pole circuit breaker frames with non-interchangeable Type A adjustable solid state trip units.

These circuit breakers are intended to be used in suitable Certified enclosures min 704 mm high by 544 mm wide by 210 mm deep.

These circuit breakers may also have a motor operated stored energy closing mechanism. They may have adjustable instantaneous (I) and long time trip (L). They may also have adjustable ground fault trip (G). They may also have adjustable short time trip (S).