



IEC SYSTEM FOR CONFORMITY  
TESTING TO STANDARDS FOR  
SAFETY OF ELECTRICAL  
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

NL-6239

## CB TEST CERTIFICATE

Issued by: KEMA Quality B.V.

Registration date: 2002-12-11

Product: Motor starters / circuit-breakers

Applicant: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany  
69123 HEIDELBERG

Manufacturer: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany  
69123 HEIDELBERG

Factory: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany  
69123 HEIDELBERG

Rating and principal characteristics: In 0,1A-0,16 A??..10A-16 A; Ue 690 Vac with Ics=Icu=max 50 kA; utilization category A; magnetic trip 12 times In;

Trade mark (if any): ABB

Model/Type reference: MS116

Additional information: -

Sample of product tested to be in conformity with IEC: 60947-2(ed.2);am1,  
60947-4-1  
(ed.1);am1;am2

Test Report Ref. No: 2024892.50, 2024892.51

This CB Test Certificate is issued by the National Certification Body

KEMA Quality B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

Signed by: H.H.M. Versteegen

Date of issue: 2002-12-11

**KEMA**