



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010307099876

NAME AND ADDRESS OF THE APPLICANT

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

TRADE MARK: ABB

NAME AND ADDRESS OF THE MANUFACTURER

Siemens AG
Nonnendammallee 101, D-13629 Berlin, Germany

NAME AND ADDRESS OF THE FACTORY

SIEMENS AG A&D CD FACTORY
Werner-von-Siemens Str. 48, D-92220 Amberg, Germany

NAME, MODEL AND SPECIFICATION

MOULDED CASE CIRCUIT BREAKER

MS495/MS496/MS497 and HK4/SK4, UA4/AA4, UA4-HK Ue: AC415/690V;
In: 16A, 20A, 25A, 32A, 40A, 50A, 63A, 75A, 90A, 100A; MS495, MS496: 415V: Ics=25kA
Icu=50kA; 690V: Ics=3kA Icu=5kA (75~100A), Ics=3kA Icu=6kA (40~63A); MS497: 415V: Ics=50kA
Icu=100kA; 690V: Ics=3kA Icu=6kA (75~100A), Ics=4kA Icu=7.5kA (63A), Ics=5kA Icu=10kA
(50A), Ics=6kA Icu=12kA (40A), Ics=7kA Icu=15kA (16~32A) A类 3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.2-2001

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED
FOR THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY
CERTIFICATION

ISSUED DATE: Dec. 12, 2003

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION
BY THE CERTIFICATION BODY AT REGULAR INTERVALS



President:

李怀林

Li Huailin

